

Laboratory

Customer :

**BRV**

Designation :

**S2 SOLAR 30**


Type number :

304651AR-12-WST6



## AIRVENTING

Airventer alone :






	M1	M2	M3
Airventing volume	47%	71%	86%



WILO test reference : 090738

Test condition :



Comments:

The airventing of the device is efficient and quick.

